

LIGHTING KEYNOTES:

LIGHT FIXTURE SCHEDULE NOTES:

1. ALL FIXTURES SUBMITTED AS "IDENTICAL" MUST BE SUBMITTED 120 DAYS PRIOR TO BID DATE.
2. ALL FLUORESCENT LAMPS SHALL HAVE A COLOR TEMPERATURE OF 3500 KELVIN AND A MINIMUM CRI OF 82, UNLESS NOTED OTHERWISE.
3. ALL LIGHT SWITCH COVER PLATES SHALL BE BRUSHED STAINLESS STEEL.
4. ALL FIXTURE COLORS SHALL BE WHITE (U.N.G.).
5. ELECTRICAL CONTRACTOR TO PROVIDE OWNER WITH SPARE LAMPS FOR EACH LAMP TYPE USED ON PROJECT. QUANTITY SHALL BE EQUAL TO 10% FOR EACH TYPE.
6. REFER TO ARCHITECTURE, REFLECTED CEILING PLANS FOR SPECIFIC FIXTURE LOCATIONS IN LAY-IN CEILINGS.
7. MOUNTING HEIGHT DIMENSIONS FOR FIXTURES WHERE LISTED, ARE TO BOTTOM OF FIXTURE.
8. WHERE MULTIPLE SWITCHES ARE SHOWN AT ONE LOCATION, THEY SHALL BE GROUPED UNDER ONE COVER PLATE.
9. ALL BALLASTS FOR LINEAR FLUORESCENT LAMPS SHALL BE PROGRAM START.
10. ALL FLUORESCENT LUMINAIRES INDICATED FOR EMERGENCY OPERATION SHALL BE CONNECTED TO THE EMERGENCY LIGHTING SYSTEM VIA A REDUCED GRID-POA OR "5X4" SLIC; PROVIDED FOR EACH SWITCHED ZONE.

No part of this drawing may be reproduced in any form or by any means, stored in a database or retrieval system, without written permission of GMB Architecture + Engineering.

```
\5-1282\5-1282\301.dgn      scottg  
JOI DATE / TIME: 6/25/2009    6:48:40 AM
```