PANELBOARD SCHEDULE

PANEL BP-E TYPE NQOD 120/208 VOLTS 3 ϕ 4 W
MOUNTING: ☐FLUSH ☒SURFACE NEUTRAL ☒100% ☐200% 225 AMP MAIN: ☒LUGS ☐BREAKER

DESCRIPTION	WATTS A	WATTS B	WATTS C	BREAKER SIZE	BREAKER POLE	CIRC.	CIRC.	BREAKER SIZE	BREAKER POLE	WATTS A	WATTS B	WATTS C	DESCRIPTION
RECEPTS - SCENE SHOP A124	360			20	1	1	2	20	1	720			RECEPTS - MECHANICAL A116
RECEPTS - SCENE SHOP A124		360		20	1	3	4	20	1		720		RECEPTS - MECHANICAL A116
RECEPTS - SCENE SHOP A124			360	20	1	5	6	20	1			180	PEQ-1 ~~(TRAP PRIMER)~~ HW
RECEPTS - SCENE SHOP A124	360			20	1	7	8	20	1	720			UH-1 (1/8 HP)
OVERHEAD DOOR SCENE SHOP A117		500		20	1	9	10	20	1		120		RECEPTS - CORRIDOR A120
~~EF-2 (1/6 HP)~~ Fire Alarm			480	20	1	11	12	20	1			180	CH-1
RECEPTS - STORAGE A119	720			20	1	13	14	20	1	720			RECEPTS - CORRIDOR A114
EF-1 (1/20 HP)		100		20	1	15	16	20	1		720		RECEPTS - CORRIDOR A113
DRYER - A119 STORAGE			864	20	1	17	18	20	1			360	EF-8 (1/8 HP)
FUTURE DRYER - A119 STORAGE	1,664			30	2	19	20	30	1	1,872			EF-11, EF-12
-		1,664		-	-	21	22	20	1				SPARE PP-1
WASHER - A119 STORAGE			864	30	1	23	24	20	1				SPARE Door opener A112
SPARE				20	1	25	26	20	1				SPARE Recep. vest B118
SPARE				20	1	27	28	20	1				SPARE " Cor A113
SPARE				20	1	29	30	20	1				SPARE Recep " "
SPARE				20	1	31	32	20	1				SPARE Recep Cor A113
SPARE				20	1	33	34	20	1				SPARE " " "
SPARE				20	1	35	36	20	1				SPARE
SPARE JCI				20	1	37	38	20	1				SPARE JCI
SPARE				20	1	39	40	20	1				SPARE
SPARE JCI				20	1	41	42	20	1				SPARE JCI
	3,104	2,624	2,568							4,032	1,560	720	

TVSS PROTECTED ☐YES ☒NO
40.55 FULL LOAD AMPS. LOCATION MECHANICAL A116

PANELBOARD SCHEDULE

PANEL BP-F TYPE NQOD 120/208 VOLTS 3 ϕ 4 W
MOUNTING: ☐FLUSH ☒SURFACE NEUTRAL ☒100% ☐200% 225 AMP MAIN: ☒LUGS ☐BREAKER

DESCRIPTION	WATTS A	WATTS B	WATTS C	BREAKER SIZE	BREAKER POLE	CIRC.	CIRC.	BREAKER SIZE	BREAKER POLE	WATTS A	WATTS B	WATTS C	DESCRIPTION
BARRIER FREE DOOR OPERATOR	500			20	1	1	2	20	1	540			RECEPTS - VESTIBULE B114
RECEPTS - VESTIBULE B103		360		20	1	3	4	20	1		900		RECEPTS - CAFETERIA B102
RECEPTS - DISPLAY CASE LOBBY B104			540	20	1	5	6	20	1			720	RECEPTS - CAFETERIA B102
RECEPTS - LOBBY B104	900			20	1	7	8	20	1	1,600			HAND DRYER - WOMEN'S TOILET B117
RECEPTS - B105, B106		720		20	1	9	10	20	1		1,600		HAND DRYER - WOMEN'S TOILET B117
RECEPTS - MEN'S TOILET B107			720	20	1	11	12	20	1			1,600	HAND DRYER - WOMEN'S TOILET B117
HAND DRYER - MEN'S TOILET B107	1,600			20	1	13	14	20	1	1,600			HAND DRYER - WOMEN'S TOILET B117
HAND DRYER - MEN'S TOILET B107		1,600		20	1	15	16	20	1		720		RECEPTS - WOMEN'S TOILET B117
HAND DRYER - MEN'S TOILET B107			1,600	20	1	17	18	20	1			540	RECEPTS - DISPLAY CASES B102
HAND DRYER - MEN'S TOILET B107	1,600			20	1	19	20	20	1	540			RECEPTS - B102, B118
RECEPTS - B112, B114		720		20	1	21	22	20	1		900		RECEPTS - CAFETERIA B102
RECEPTS - TICKETS B110			720	20	1	23	24	20	1			180	CH-3
RECEPTS - OFFICE B111	720			20	1	25	26	20	1	500			BARRIER FREE DOOR OPERATOR
SPARE				20	1	27	28	20	1		180		RECEPTS - CORRIDOR A113
SPARE				20	1	29	30	20	1			180	RECEPTS - CORRIDOR A113
SPARE				20	1	31	32	20	1	180			RECEPTS - CORRIDOR A113
SPARE				20	1	33	34	20	1		180		RECEPTS - CORRIDOR A113
SPARE				20	1	35	36	20	1				SPARE
SPARE				20	1	37	38	20	1				SPARE
SPARE				20	1	39	40	20	1				SPARE
SPARE				20	1	41	42	20	1				SPARE
	5,320	3,400	3,580							4,960	4,480	3,220	

TVSS PROTECTED ☐YES ☒NO
69.28 FULL LOAD AMPS. LOCATION STORAGE B112

PANELBOARD SCHEDULE

PANEL BP-J TYPE NQOD 120/208 VOLTS 3 ϕ 4 W
MOUNTING: ☐FLUSH ☒SURFACE NEUTRAL ☒100% ☐200% 100 AMP MAIN: ☒LUGS ☐BREAKER

DESCRIPTION	WATTS A	WATTS B	WATTS C	BREAKER SIZE	BREAKER POLE	CIRC.	CIRC.	BREAKER SIZE	BREAKER POLE	WATTS A	WATTS B	WATTS C	DESCRIPTION
RECEPT - ELECTRICAL A202	360			20	1	1	2	20	1	540			RECEPTS - ROOF PERIMETER
RECEPT - ELECTRICAL A202		360		20	1	3	4	20	1		540		~~RECEPTS - CATWALK~~ EF12
RECEPT - ELECTRICAL A202			360	20	1	5	6	20	1				SPARE A201 Recept
RECEPT - ELECTRICAL A202	360			20	1	7	8	20	1				SPARE " "
RECEPT - ELECTRICAL A202		180		20	1	9	10	20	1				SPARE
~~RECEPT - ELECTRICAL A202~~ Heater A201			180	20	1	11	12	20	1				SPARE
MOTORIZED DAMPERS A201	960			20	1	13	14	20	1				SPARE
PEQ-15 (TRAP PRIMER)		180		20	1	15	16	20	1				SPARE
SPARE Electrical A202				20	1	17	18	20	1				SPARE
SPARE Electrical A202				20	1	19	20	20	1				SPARE
SPARE				20	1	21	22	20	1				SPARE
SPARE				20	1	23	24	20	1				SPARE
SPARE				20	1	25	26	20	1				SPARE
SPARE				20	1	27	28	20	1				SPARE
SPARE				20	1	29	30	20	1				SPARE
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	XXXXX			XXXXX	XXXXX	31	32	XXXXX	XXXXX	XXXXX			XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX		XXXXX		XXXXX	XXXXX	33	34	XXXXX	XXXXX		XXXXX		XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX			XXXXX	XXXXX	XXXXX	35	36	XXXXX	XXXXX			XXXXX	XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	XXXXX			XXXXX	XXXXX	37	38	XXXXX	XXXXX	XXXXX			XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX		XXXXX		XXXXX	XXXXX	39	40	XXXXX	XXXXX		XXXXX		XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX			XXXXX	XXXXX	XXXXX	41	42	XXXXX	XXXXX			XXXXX	XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
	1,680	720	540							540	540	-	

TVSS PROTECTED ☐YES ☒NO
11.16 FULL LOAD AMPS. LOCATION ELECTRICAL A202

PANELBOARD SCHEDULE

PANEL BP-Q TYPE NQOD 120/208 VOLTS 3 ϕ 4 W
MOUNTING: ☐FLUSH ☒SURFACE NEUTRAL ☒100% ☐200% 100 AMP MAIN: ☒LUGS ☐BREAKER

DESCRIPTION	WATTS A	WATTS B	WATTS C	BREAKER SIZE	BREAKER POLE	CIRC.	CIRC.	BREAKER SIZE	BREAKER POLE	WATTS A	WATTS B	WATTS C	DESCRIPTION
LIGHTING CONTROL PANEL 'H'	500			20	1	1	2	20	1	540			RECEPTS - ROOF PERIMETER
RECEPTS - STORAGE B203		720		20	1	3	4	20	1		720		RECEPTS - CATWALK
RECEPTS - AUDITORIUM HOUSE B119			540	20	1	5	6	20	1			720	RECEPTS - CATWALK
RECEPTS - CONTROL ROOM B202	540			20	1	7	8	20	1	900			RECEPTS - CATWALK, FOLLOW SPOT
RECEPT - B202 PLUG MOLD		180		20	1	9	10	20	1		900		RECEPTS - FOLLOW SPOT / MECH.
RECEPT - B202 PLUG MOLD			180	20	1	11	12	20	1			720	RECEPTS - ROOF PERIMETER
RECEPT - B202 PLUG MOLD	180			20	1	13	14	20	1				SPARE
RECEPT - B202 PLUG MOLD		180		20	1	15	16	20	1				SPARE
RECEPT - B202 PLUG MOLD			180	20	1	17	18	20	1				SPARE
RECEPTS - CONTROL ROOM B202	540			20	1	19	20	20	1				SPARE
RECEPTS - B201, B119		1,080		20	1	21	22	20	1				SPARE
RECEPTS - ELECTRICAL B206			540	20	1	23	24	20	1				SPARE
SPARE				20	1	25	26	20	1				SPARE
SPARE				20	1	27	28	20	1				SPARE
SPARE				20	1	29	30	20	1				SPARE
SPARE				20	1	31	32	20	1				SPARE
SPARE				20	1	33	34	20	1				SPARE
SPARE				20	1	35	36	20	1				SPARE
SPARE				20	1	37	38	20	1				SPARE
SPARE				20	1	39	40	20	1				SPARE
SPARE				20	1	41	42	20	1			96	LOW VOLTAGE WALL MTD. TRACK
	1,760	2,160	1,440							1,440	1,620	1,536	

TVSS PROTECTED ☐YES ☒NO
27.64 FULL LOAD AMPS. LOCATION STORAGE B203

PANELBOARD SCHEDULE

PANEL BP-AP TYPE NQOD 120/208 VOLTS 3 ϕ 4 W
MOUNTING: ☐FLUSH ☒SURFACE NEUTRAL ☒100% ☐200% 80 AMP MAIN: ☐LUGS ☒BREAKER

DESCRIPTION	WATTS A	WATTS B	WATTS C	BREAKER SIZE	BREAKER POLE	CIRC.	CIRC.	BREAKER SIZE	BREAKER POLE	WATTS A	WATTS B	WATTS C	DESCRIPTION
BLAST CHILLER COND. UNIT (ITEM 3.8)	4,804			50	3	1	2	20	1	500			FREEZER LIGHTS (ITEM 3.2)
-		4,804		-	-	3	4	20	3		1,093		REFRIGERATOR COND. UNIT (ITEM 3.4)
-			4,804	-	-	5	6	-	-			1,093	-
BLAST CHILLER EVAP. (ITEM 3.7)	1,201			20	3	7	8	-	-	1,093			-
-		1,201		-	-	9	10	20	1		264		REFRIGERATOR EVAP. (ITEM 3.3)
-			1,201	-	-	11	12	20	1			500	REFRIGERATOR LIGHTS (ITEM 3.1)
FREEZER CONDENSING UNIT (ITEM 3.6)	2,690			30	3	13	14						SPARE
-		2,690		-	-	15	16						SPARE
-			2,690	-	-	17	18						SPARE
FREEZER EVAPORATOR (ITEM 3.5)	1,851			30	2	19	20						SPARE
-		1,851		-	-	21	22						SPARE
SPARE						23	24						SPARE
SPARE						25	26						SPARE
SPARE						27	28						SPARE
SPARE						29	30						SPARE
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	XXXXXX			XXXXX	XXXXX	31	32	XXXXX	XXXXX	XXXXXX			XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX		XXXXXX		XXXXX	XXXXX	33	34	XXXXX	XXXXX		XXXXXX		XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX			XXXXXX	XXXXX	XXXXX	35	36	XXXXX	XXXXX			XXXXXX	XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	XXXXXX			XXXXX	XXXXX	37	38	XXXXX	XXXXX	XXXXXX			XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX		XXXXXX		XXXXX	XXXXX	39	40	XXXXX	XXXXX		XXXXXX		XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX			XXXXXX	XXXXX	XXXXX	41	42	XXXXX	XXXXX			XXXXXX	XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
	10,546	10,546	8,694							1,593	1,357	1,593	

TVSS PROTECTED ☐YES ☒NO
95.29 FULL LOAD AMPS. LOCATION MECHANICAL A116

PANELBOARD SCHEDULE

PANEL PP-EMA TYPE NF 277/480 VOLTS 3 ϕ 4 W
MOUNTING: ☐FLUSH ☒SURFACE NEUTRAL ☒100% ☐200% 100 AMP MAIN: ☐LUGS ☒BREAKER

DESCRIPTION	WATTS A	WATTS B	WATTS C	BREAKER SIZE	BREAKER POLE	CIRC.	CIRC.	BREAKER SIZE	BREAKER POLE	WATTS A	WATTS B	WATTS C	DESCRIPTION
SOUTH ADDITION EMERGENCY LTG	1,522					1	2						CONTROL/TOILET RM EMERG. LTG
CORRIDOR EMERGENCY LIGHTING		1,246				3	4				1,232		CAFETERIA EMERGENCY LIGHTING
NORTH CAFETERIA EMERG. LIGHTING			1,808			5	6					1,440	KITCHEN/SERVERY EMERGENCY LTG
ELEVATOR PIT LIGHTING	72					7	8			616			UPPER AUDITORIUM EMERGENCY LTG
CATWALK EMERGENCY LIGHTING		468				9	10				1,872		AUD. HOUSE EMERGENCY LIGHTING
SPARE						11	12						SPARE
SPARE						13	14						SPARE
SPARE						15	16						SPARE
SPARE						17	18						SPARE
SPARE						19	20						SPARE
SPARE						21	22						SPARE
SPARE						23	24						SPARE
SPARE						25	26						SPARE
SPARE						27	28						SPARE
SPARE						29	30						SPARE
SPARE						31	32						SPARE
SPARE						33	34						SPARE
SPARE						35	36						SPARE
SPARE						37	38						SPARE
SPARE						39	40						SPARE
SPARE						41	42						SPARE
	1,594	1,714	1,808							616	3,104	1,440	

TVSS PROTECTED ☐YES ☒NO
12.36 FULL LOAD AMPS. LOCATION MECH/ELEC B127

PANELBOARD SCHEDULE

PANEL LP-G TYPE NF 277/480 VOLTS 3 ϕ 4 W
MOUNTING: ☐FLUSH ☒SURFACE NEUTRAL ☒100% ☐200% 250 AMP MAIN: ☐LUGS ☒BREAKER

DESCRIPTION	WATTS A	WATTS B	WATTS C	BREAKER SIZE	BREAKER POLE	CIRC.	CIRC.	BREAKER SIZE	BREAKER POLE	WATTS A	WATTS B	WATTS C	DESCRIPTION
LTG-MECH/ELEC/STOR/DRESSING RMS	2,860			20	1	1	2	20	1	1,472			LTG - MECHANICAL MEZZANINE
LTG - DANCE/GREEN ROOM		1,156		20	1	3	4	20	1		1,264		LTG - CORRIDORS A114, A115
LTG - CORRID. B105,123, 128, 131			900	20	1	5	6	20	1			890	LTG - TECH DECKS/LOADING GALLERY
LTG - AUDITORIUM SCONCE LIGHTS	414			20	1	7	8	20	1	1,248			HOUSE LTG - WEST AUDITORIUM
LTG - AUDITORIUM CATWALK		468		20	1	9	10	20	1		1,560		HOUSE LTG - CENTER AUDITORIUM
LTG - MECHANICAL MEZZANINE			1,288	20	1	11	12	20	1			1,248	HOUSE LTG - EAST AUDITORIUM
SPARE				20	1	13	14	20	1	1,872			HOUSE LTG - AUDIT. EMERG. LIGHTS
SPARE				20	1	15	16	20	1				SPARE
SPARE				20	1	17	18	20	1				SPARE
SPARE				20	1	19	20	20	1				SPARE
SPARE				20	1	21	22	20	1				SPARE HEATER
SPARE				20	1	23	24	20	1				SPARE " "
SPARE				20	1	25	26	20	1				SPARE " "
SPARE				20	1	27	28	20	1				SPARE " "
SPARE				20	1	29	30	20	1				SPARE
SPARE				20	1	31	32	20	1				SPARE
SPARE				20	1	33	34	20	1				SPARE
SPARE				20	1	35	36	20	1				SPARE
SPARE				20	1	37	38	20	1				SPARE
SPARE				20	1	39	40	20	1		AEC XX		SPARE
SPARE				20	1	41	42	20	1				SPARE KB
	3,274	1,624	2,188							4,592	2,824	2,138	

TVSS PROTECTED ☐YES ☒NO
20.01 FULL LOAD AMPS. LOCATION MECH/ELEC B127

PANELBOARD SCHEDULE

PANEL LP-H TYPE NF 277/480 VOLTS 3 ϕ 4 W
MOUNTING: ☐FLUSH ☒SURFACE NEUTRAL ☒100% ☐200% 225 AMP MAIN: ☐LUGS ☒BREAKER

DESCRIPTION	WATTS A	WATTS B	WATTS C	BREAKER SIZE	BREAKER POLE	CIRC.	CIRC.	BREAKER SIZE	BREAKER POLE	WATTS A	WATTS B	WATTS C	DESCRIPTION
CAFETERIA GENERAL LIGHTING	2,632			20	1	1	2	20	1	1,640			LTG - CAFETERIA/BLDG ENTRANCES
CAFETERIA GENERAL LIGHTING		2,688		20	1	3	4	20	1		1,768		LTG - TOILET/STORAGE ROOMS
CAFETERIA TYPE 'FF' PENDANT LIGHTS			2,816	20	1	5	6	20	1			576	LTG - CAFETERIA 'FP' PENDANT LIGHTS
CAFETERIA TYPE 'FD' DOWN LIGHTS	3,072			20	1	7	8	20	1	864			LTG - KITCHEN SERVERY 'FD8' LIGHTS
LTG - CORRIDOR A113		1,804		20	1	9	10	20	1		612		LTG - KITCHEN SERVERY 'FP4' LIGHTS
LTG - CONTROL ROOM LEVEL			1,174	20	1	11	12	20	1			1,470	LTG - KITCHEN/DRY STORAGE
BLDG EXTERIOR LIGHTING	697			20	1	13	14	20	1	340			DISPLAY CASE LIGHTING
SITE WALK-WAY BOLLARDS		490		20	1	15	16	20	1		840		LTG-FOLLOWSPOT/MECHANICAL ROOM
NORTH PARKING LOT			794	20	1	17	18	20	1			60	LTG - ELEVATOR EQUIPMENT ROOM
SOUTH PARKING LOT	432			20	1	19	20	60	3	7,482			ELEVATOR (20 HP)
LTG - AUDITORIUM VESTIBULES		288		20	1	21	22	-	-		7,482		-
SPARE				20	1	23	24	-	-			7,482	-
HP-7	3,048			15	3	25	26	20	3	2,500			CH-2A
-		3,048		-	-	27	28	-	-		2,500		-
-			3,048	-	-	29	30	-	-			2,500	-
HP-14	2,411			15	3	31	32	20	3	2,500			CH-2B
-		2,411		-	-	33	34	-	-		2,500		-
-			2,411	-	-	35	36	-	-			2,500	-
HP-15	2,411			15	3	37	38	20	1				SPARE
-		2,411		-	-	39	40	20	1				SPARE
-			2,411	-	-	41	42	20	1				SPARE
	14,703	13,140	12,654							15,326	15,702	14,588	

TVSS PROTECTED ☐YES ☒NO
103.58 FULL LOAD AMPS. LOCATION ELETRICAL B206

PANELBOARD SCHEDULE

PANEL ___ TYPE ___ ___ VOLTS ___ ϕ ___ W
MOUNTING: ☐FLUSH ☐SURFACE NEUTRAL ☐100% ☐200% ___ AMP MAIN: ☐LUGS ☐BREAKER

DESCRIPTION	WATTS A	WATTS B	WATTS C	BREAKER SIZE	BREAKER POLE	CIRC.	CIRC.	BREAKER SIZE	BREAKER POLE	WATTS A	WATTS B	WATTS C	DESCRIPTION
						1	2						
						3	4						
						5	6						
						7	8						
						9	10						
						11	12						
						13	14						
						15	16						
						17	18						
						19	20						
						21	22						
						23	24						
						25	26						
						27	28						
						29	30						
						31	32						
						33	34						
						35	36						
						37	38						
						39	40						
						41	42						

TVSS PROTECTED ☐YES ☐NO
___ FULL LOAD AMPS. LOCATION ___

PANELBOARD SCHEDULE

PANEL ___ TYPE ___ ___ VOLTS ___ ϕ ___ W
MOUNTING: ☐FLUSH ☐SURFACE NEUTRAL ☐100% ☐200% ___ AMP MAIN: ☐LUGS ☐BREAKER

DESCRIPTION	WATTS A	WATTS B	WATTS C	BREAKER SIZE	BREAKER POLE	CIRC.	CIRC.	BREAKER SIZE	BREAKER POLE	WATTS A	WATTS B	WATTS C	DESCRIPTION
						1	2						
						3	4						
						5	6						
						7	8						
						9	10						
						11	12						
						13	14						
						15	16						
						17	18						
						19	20						
						21	22						
						23	24						
						25	26						
						27	28						
						29	30						
						31	32						
						33	34						
						35	36						
						37	38						
						39	40						
						41	42						

TVSS PROTECTED ☐YES ☐NO
___ FULL LOAD AMPS. LOCATION ___

OA Tem
SA Tem
OA.

BP-4 LOAD PANEL (BY EC)

CKT #	DESCRIPTION	LOAD	CKT #	DESCRIPTION	LOAD
1	RP1-1	1500	25	RP1-2	1500
3	RP1-3	1500	26	RP1-4	1500
5	RP1-5	1500	27	RP1-6	1500
7	RP1-7	1500	28	RP1-8	1500
9	SPARE	1500	29	RP1-10	1500
11	RP1-11	1500	30	RP1-12	1500
13	RP1-13	1500	31	RP1-14	1500
15	RP1-15	1500	32	RP1-16	1500
17	OUTLET BOX X - FOLLOWSPOT	1750	33	OUTLET BOX Y - FOLLOWSPOT	1750
19	RP1-19	1500	34	RP1-20	1500
21	RP1-21	1500	35	RP1-22	1500
23	RP1-23	1500	36	RP1-24	1500
25	FP-4	500	37	SMP	500
27	AUX RACK OUTLET	500	38	TECH BOOTH	500
29	RP1-29	1500	39	RP1-30	1500
31	RP1-31	1500	40	RP1-32	1500
33	RP1-33	1500	41	RP1-34	1500
35	RP1-35	1500	42	RP1-36	1500
37	RP1-37	1500	43	RP1-38	1500
39	RP1-39	1500	44	RP1-40	1500
41	SPARE	1500	45	SPARE	1500

GMB Architects • Engineers
85 East Eighth Street, Suite 200
Holland, MI 49423

REVISIONS
ISSUANCES
DRAWN BY RCG

FINE ARTS CENTER ADDITION
WAYLAND UNION SCHOOLS
WAYLAND, MICHIGAN

PROJECT NO. 5-1282
Copyright © 2009
GMB Architects • Engineers
All Rights Reserved

PANELBOARD SCHEDULES

E5.02

No part of this drawing may be reproduced in any form or by any means, stored in a database or retrieval system, without written permission of GMB Architecture + Engineering.

g:\5-1282\5-1282E502.dgn
PLOT DATE / TIME: 6/25/2009 6:49:03 AM
scottg