


THIS DRAWING IS FOR CONCEPTUAL AND BID PURPOSES ONLY, AND IS NOT TO BE USED AS A CONSTRUCTION DRAWING



HOOD INFORMATION													
HOOD NO.	TAG	MODEL	LENGTH	MAX. COOKING TEMP.	EXHAUST PLENUM				SUPPLY PLENUM				HOOD CONFIG.
					TOTAL EXH. CFM	WIDTH	LENG.	DIA.	CFM	S.P.	TOTAL SUP. CFM	WIDTH	
11A	Item #11A (Left)	6024	11' 9.00"	600 Deg.	2820	10"	27"	2820	-0.533"	2256			304 SS
11B	Item #11B (Right)	6024	11' 9.00"	600 Deg.	2820	10"	27"	2820	-0.533"	2256			304 SS
78A	Item #78A	4224	7' 0.00"	600 Deg.	1750	10"	16"	1750	-0.454"	0			304 SS
78B	Item #78B	4224	7' 0.00"	600 Deg.	1750	10"	16"	1750	-0.454"	0			304 SS
78 PSP1	Item #78 PSP1	96	8' 6.00"	300 Deg.	0					768			304 SS
78 PSP2	Item #78 PSP2	96	8' 6.00"	300 Deg.	0					768			304 SS
78 PSP3	Item #78 PSP3	96	7' 0.00"	300 Deg.	0					632			304 SS
78 PSP4	Item #78 PSP4	96	7' 0.00"	300 Deg.	0					632			304 SS
46	Item #46	4824	5' 6.00"	600 Deg.	1375	10"	13"	1375	-0.453"	1100			304 SS
99	Item #99	4824	5' 0.00"	450 Deg.	1000	10"	9"	1000	-0.319"	800			304 SS

HOOD INFORMATION													
HOOD NO.	TYPE	QTY.	HEIGHT	LENGTH	QTY.	LIGHT(S)				WIRE GUARD	LOCATION	FIRE SYSTEM	HOOD WEIGHT
						TYPE	LOCATION	TYPE	SIZE				
11A	SS Baffle with Handles	7	16"	20"	2	4' Fluorescent Light, F	NO					NO	795 LBS
11B	SS Baffle with Handles	7	16"	20"	2	4' Fluorescent Light, F	NO					NO	795 LBS
78A	SS Baffle with Handles	4	16"	16"	1	4' Fluorescent Light, F	NO					NO	285 LBS
78B	SS Baffle with Handles	4	16"	16"	1	4' Fluorescent Light, F	NO					NO	285 LBS
78 PSP1					0							NO	60 LBS
78 PSP2					0							NO	60 LBS
78 PSP3					0							NO	54 LBS
78 PSP4					0							NO	54 LBS
46	SS Baffle with Handles	4	16"	16"	1	4' Fluorescent Light, F	NO					NO	456 LBS
99	SS Baffle with Handles	3	16"	20"	1	3' Fluorescent Light, F	NO					NO	374 LBS

HOOD OPTIONS													
HOOD NO.	OPTION												
11A	BACKSPLASH	80.00"	High	X	141.00"	Long	304	SS					
	FIELD WRAPPER	18.00"	High			Front, Left							
	LEFT END PANEL	54"	Top Width,	48"	Bottom Width,	45"	High	304	SS				
11B	BACKSPLASH	80.00"	High	X	141.00"	Long	304	SS					
	FIELD WRAPPER	18.00"	High			Front, Right							
	LEFT END PANEL	54"	Top Width,	48"	Bottom Width,	45"	High	304	SS				
78 PSP1	WRAPPER CHANNEL	Front, Left, Right (1 WRAPPER FOR EACH SIDE @ 102" LENGTH)											
78 PSP2	WRAPPER CHANNEL	Front, Left, Right (1 WRAPPER FOR EACH SIDE @ 102" LENGTH)											
78 PSP3	WRAPPER CHANNEL	Front (1 WRAPPER FOR EACH SIDE @ 102" LENGTH)											
78 PSP4	WRAPPER CHANNEL	Front (1 WRAPPER FOR EACH SIDE @ 102" LENGTH)											
46													
	FIELD WRAPPER	18.00"	High			Front, Left, Right							
	RIGHT END PANEL	48"	Top Width,	42"	Bottom Width,	45"	High	304	SS				
	LEFT QUARTER END PANEL	23"	Top Width,	0"	Bottom Width,	23"	High	304	SS				
99	BACKSPLASH	80.00"	High	X	60.00"	Long	304	SS					
	FIELD WRAPPER	18.00"	High			Front, Left, Right							

PERFORATED SUPPLY PLENUM(S)													
HOOD NO.	POS.	LENGTH	WIDTH	HEIGHT	RISE(S)				S.P.				
					WIDTH	LENG.	DIA.	CFM		WIDTH	LENG.	DIA.	CFM
11A	Front	141"	16"	6"	10"	28"		1128	0.166"				
11B	Front	141"	16"	6"	10"	28"		1128	0.166"				
78 PSP1	Front	102"	9"	6"	6"	16"		384	0.074"				
78 PSP2	Front	102"	9"	6"	6"	16"		384	0.074"				
78 PSP3	Front	84"	9"	6"	6"	16"		316	0.051"				
78 PSP4	Front	84"	9"	6"	6"	16"		316	0.051"				
46	Front	66"	16"	6"	10"	28"		1100	0.158"				
99	Front	60"	12"	6"	8"	24"		800	0.126"				

RESIDENTS: JUNE 24, 2009

DESIGNER: FINE ARTS CENTER ADDITION

DATE: JUNE 24, 2009

BY: [Signature]

FINE ARTS CENTER ADDITION
WAYLAND UNION SCHOOLS
WAYLAND MICHIGAN

VENTILATION PLAN
FS6